

Role of Current Relays in Compressor Ignition

Site: Mbsmpro

Date: January 29, 2026 | **Author:** www.mbsmpro.com

URL: <https://mbsmpro.com/role-of-current-relays-in-compressor-ignition/>

CHARACTERISTIC TABLES OF VARIOUS START AND PROTECTION STEMS

CURRENT RELAYS




Model	Compressor horse (HP)	Terminal	Apply current(I)	Applied current (A)
117U 2010	1/3	5	4.5	4.5
117U 2100	1/4	6	3	3.6
117U 2104	1/5	4	6.6	6.5
117U 2050	1/2	1	14	1.4

THERMAL OVERLOAD PROTECTORS



Compressor power (HP)	1/2	1/3	1/4	1/5	1/6	1/2
Max Connect current (A)	12.5	9	9.8	7.5	7	5
Max Connect current (A)	19	16	14	3.5	3.5	3.5
Max release (A)	5	4.75	4	3.5	3	3.3



THERMAL OVERLOAD PROTECTORS

Compressor power (HP)	1/2	1/3	1/4	1/5	1/6	1/2
Power Model	153	12.5	9	8	7.5	7
Max connect current (A)	6	4.05	3.65	4	3.5	3.5
Release current (A)	5	4.75	4	3.5	3	3

Compressor power (HP)	Compressor power (HP)	Max connect current (A)	Minimum release
	6563	6.63	1.93
1/2	BEA15	2.8	2.8
1/3	BEA10	3.8	3.6
1/4	BGA11	1.25	3.25
1/5	BGA11	1.75	3.55



THERMAL OVERLOAD PROTECTOR CAPS

Compressor power (HP)	Overload current (A)	Movement temperature	Applied current (113±10%)	Reply return current temperatures
5	35	125±10°C	JET+ TEW	60±10°C
1/2	30		JET+ TEW	
1/4	25		JET+ TEW	



Mbsmpro.com, Compressor Spare Parts, Relays, Thermal Overload Protectors, 1/2 hp to 1/6 hp, Start and Protection Stems, Characteristic Tables

Selecting the right electrical components is the heartbeat of refrigeration maintenance. When a compressor fails to start or constantly trips, the culprit is often a mismatched **Current Relay** or a fatigued **Thermal Overload Protector**. Ensuring these parts align perfectly with the compressor's horsepower (HP) and amperage rating is not just about repair—it is about system longevity.

The Role of Current Relays in Compressor Ignition

Current relays are electromagnetic switches that momentarily engage the start winding of a compressor. Once the motor reaches approximately 75% of its rated speed, the relay disconnects the start winding, allowing the motor to run on its main winding.

Technical Specifications for Standard Current Relays

Model	Compressor Power (HP)	Terminal Pin	Applied Current (A)
117U 2010	1/3 HP	5	4.5 A
117U 2100	1/4 HP	6	3.6 A

Model	Compressor Power (HP)	Terminal Pin	Applied Current (A)
117U 2104	1/5 HP	4	6.5 A
117U 2050	1/2 HP	1	1.4 A

Thermal Overload Protectors: The Safety Net

Thermal Overload Protectors (TOP) act as a bimetallic fuse. They monitor both the heat generated by the compressor and the current flowing through it. If the compressor stalls (locked rotor) or overheats due to a refrigerant leak, the TOP breaks the circuit to prevent the motor windings from melting.

Performance Benchmarks for Overload Protectors

Compressor Power (HP)	Max Connect Current (A)	Release Current (A)
1/2 HP	12.5 A	5.0 A
1/3 HP	9.0 A	4.75 A
1/4 HP	8.0 A	4.0 A
1/5 HP	7.5 A	3.5 A
1/6 HP	7.0 A	3.0 A

Comparison: Mechanical Relays vs. PTC Starters

While the technical data above focuses on mechanical current relays, modern systems often use **PTC (Positive Temperature Coefficient)** starters.

- **Mechanical Relays (117U Series):** Highly reliable for heavy-duty applications. They provide a “snap” action that is better for high-torque starts.
- **PTC Starters:** Use a solid-state disk that increases resistance as it heats up. They are quieter but require a cool-down period before the compressor can restart.

Engineering Advice for Field Technicians

1. **Never Oversize the Protector:** If you install a 1/2 HP protector on a 1/6 HP compressor, the protector will not trip during a fault, leading to a burnt-out compressor.
2. **Check the Return Temperature:** Thermal caps must operate within a return temperature range of **60 ± 10°C**. Anything higher indicates a system restriction or lack of airflow over the condenser.
3. **Terminal Integrity:** Ensure terminals are tight. A loose connection creates resistance, which generates heat and causes “nuisance tripping” of the overload.

Focus Keyword: Compressor Current Relay and Thermal Overload Protector Characteristic Tables for 1/2 to 1/6 HP

SEO Title: Mbsmpro.com | Compressor Start Relays & Thermal Overload Tables

Meta Description: Comprehensive guide to compressor start and protection stems. Technical tables for 117U relays and thermal overload protectors from 1/2 HP to 1/6 HP. Essential data for HVAC engineers.

Slug: compressor-relay-thermal-overload-characteristic-tables

Tags: Mbsmgroup, Mbsm.pro, mbsmpro.com, mbsm, Compressor Parts, Start Relay, Thermal Overload, Refrigeration Repair, 117U Relay, HVAC Engineering, Compressor Protection.

Excerpt: Selecting the right electrical components is the heartbeat of refrigeration maintenance. When a compressor fails to start or constantly trips, the culprit is often a mismatched Current Relay or a fatigued Thermal Overload Protector. Ensuring these parts align perfectly with the compressor’s horsepower (HP) and amperage rating is vital for long-term system reliability.

CHARACTERISTIC TABLES OF VARIOUS START AND PROTECTION STEMS

CURRENT RELAYS



Model	Compressor horse (HP)	Terminal	Apply current(I)	Applied current (A)
117U 2010	1/3	5	4.5	4.5
117U 2100	1/4	6	3	3.6
117U 2104	1/5	4	6.6	6.5
117U 2050	1/2	1	14	1.4

THERMAL OVERLOAD PROTECTORS



Compressor power (HP)	1/2	1/3	1/4	1/5	1/6	1/2
Max Connect current (A)	12.5	9	9.8	7.5	7	5
Max Connect current (A)	19	16	14	3.5	3.5	3.5
Max release (A)	5	4.75	4	3.5	3	3.3



THERMAL OVERLOAD PROTECTORS

Compressor power (HP)	1/2	1/3	1/4	1/5	1/6	1/2
Power Model	151	12.5	9	8	7.5	7
Max connect current (A)	8	4.05	3.65	4	3.5	3.5
Release current (A)	5	4.75	4	3.5	3	3

Compressor power (HP)	Compressor power (HP)	Max connect current (A)	Minimum release
	858J	6.63	1.93
1/2	BEA15	2.8	2.8
1/3	BEA10	3.8	3.6
1/4	BGA11	1.25	3.25
1/5	BGA11	1.75	3.55



THERMAL OVERLOAD PROTECTOR CAPS

Compressor power (HP)	Overload current (A)	Movement temperature	Applied current (1133+10.%)	Reply return numment temperatures
5	35	125±10°C	JET+TEW	60±10°C
1/2	30		JET+TEW	
1/4	25		JET+TEW	



Role of Current Relays in Compressor Ignition mbsmpro

[mbsmpro.com-Role of Current Relays in Compressor Ignition](https://mbsmpro.com/Role-of-Current-Relays-in-Compressor-Ignition)Download

Latest Articles

- [Guide de Dépannage de la Carte Inverter : Climatiseur Kolin KSM-IW20WAE](#)
- [RCFF-2HP Capillary Tube for a Samsung 18000 BTU air conditioner](#)
- [Carbon brushes washing machine motors](#)
- [Chauffe-eau Junkers : Restauration d'un Classique](#)
- [WS57H Compressor, 1/6 hp, Capacitor Requirement 4mf](#)
- [Hisense inverter expert, installtion](#)
- [Copeland D3DS5-100X 10 HP Freezer Compressor](#)
- [Bitzer 6G-30.2Y: The High-Performance 30 HP Semi-Hermetic](#)
- [Réparer un chauffe-eau à gaz Olympic 6L](#)
- [Best piping practices for semi-hermetic systems](#)
- [Core ChauffeEau Junkers Mid-1980s to Late 1990s](#)
- [Not recommended R410A to R407c](#)
- [Details of refrigerant R134a](#)
- [The electrical circuit for a timer-based steam refrigerator is an interesting one](#)
- [Changing Filter 1/5 Hp](#)
- [1/5 HP Compressor oil change: How much and how to do it right](#)
- [Deep cleaning AC units from A to Z... that's our craft](#)
- [Plumbing Fittings Explained](#)
- [Can the GL80 compressor be installed in place of the GL90?](#)
- [The process of replacing the air conditioner compressor is successful, and it is working as it was before ?](#)

